



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **Sungrow Power Supply Co., Ltd.**
No.1699 Xiyou Rd, New & High Technology Industrial Development Zone, Hefei,
230088
P.R.China

Product: **Grid-tied Photovoltaic (PV) inverter**

Model **SG125CX-P2**
SG110CX-P2
SG75CX-P2

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Firmware version: **LCD_GARNET-S_V11_V01_A**
MDSP_GARNET-S_V11_V01_A

Connection rule: **IRR-DCC-MV Version 2:2016**
Intermittent Renewable Resources (Wind and PV) Distribution Connection Code (DCC) At Medium Voltage (MV)
IEC 61727:2004
Photovoltaic (PV) systems – Characteristics of the utility interface
IEC 62116:2008 / IEC 62116:2014
Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

Standards / directives for testing: FGW TG3, Rev. 25: 2018-09-01, referencing IEC 61400-21 Ed. 2: 2008 and 61000-4-7: 2008
CEI 0-16:2019-04
IEC 62116:2014
IEC 61727:2004

Report number: **SGR-ESH-P22090254** **Certification scheme:** **NSOP-0032-DEU-ZE-V01**
Certificate number: **U23-0029** **Date of issue:** **2023-01-20**

Certification body

Alf Assenkamp



*Certification body of Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065
A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH*